

## Medical Gas Room Label


Interior signs may be created using an office printer (laminating is recommended). Signs exposed to the weather may require special consideration. Signs shall be visible from a distance of 5ft.

Any of the following are considered acceptable signage for Medical Gas Rooms:

### NFPA 704 Diamonds

Both oxygen and nitrous oxide are present in a liquid state when compressed for tank storage. In the liquid state the health hazard is higher than in the gaseous state. (The words in blue are for reference and are not part of the actual sign.)

Compressed (liquefied) Oxygen or Nitrous Oxide: May cause severe frost bite.  
[Nitrous Oxide: May cause rapid asphyxiation.]



Caution:  
Oxidizing Gas(es) Stored Within  
No Smoking

Or

Caution:  
Medical Gases  
No Smoking

Or

Labeling the door with the type  
of medical gas stored.

**NITROUS OXIDE**

Or

**OXYGEN**

## Examples of Medical Gas Pipe Direction Labels

Labels can be ordered on-line from any retailer or may be created in-house as long as they are permanent in nature. The following are examples

