



SPOKANE VALLEY FIRE DEPARTMENT

Est. 1940

Bryan Collins, Fire Chief
2120 N. Wilbur
Spokane Valley, WA 99206
Phone (509) 928-1700
FAX (509) 892-4125
www.spokanevalleyfire.com

SITE PLAN DRAWING REQUIREMENTS

A Complete and Accurate Submittal Must Include the Following:

1. Drawings shall be 24"x36" sheets to scale.
2. The information provided on the drawings to include, but not be limited to:
 - a. Name of owner & occupant and street address.
 - b. Vicinity map: show relation of project to nearby parcels (include streets).
 - c. Point of compass and graphic representation of scale.
 - d. Provide information on the building (include square footage, height to eave, construction type).
 - e. The location of existing fire hydrants located within 300 ft. of the site.
 - f. Location of new fire hydrants.
 - g. Note fire department access roads, fire lanes and turnarounds/hammerheads.
3. The issuance of a permit based upon plans, data and other reports shall not prevent the Fire Department from thereafter requiring correction of deficiencies. Any deficiencies found during field inspection, testing or Fire Company surveys must also be corrected.